



GOLDLINE LABORATORIES PVT. LTD.

B-85, G.T.karnal Road, Industrial Area, Delhi-110033, Ph: 91-11-45201100, 45686073
Fax: 91-11-27413437, 45201198, E-mail: drjindal@rdgc.in, website: <http://www.rapididiagnostic.in>

TO WHOMSOEVER IT MAY CONCERN

This is to confirm that the FEDI 2-10- Rx stacks manufactured by M/s QUA Water technology Pvt. have been installed in our water system project as per the details given below.

A. Specification:

- FEDI Flow : 1.0 M3/ Hour
- Application : Pharmaceutical –USP grade
- Location : G.T Karnal Road, Industrial area, Delhi

B. Pretreatment : Double Pass RO/ Two pass RO

C. Product : FEDI 2-10- Rx


D. No of stacks : 01

E. Permeate Conductivity : 0.2 μ s/cm

F. Date of Commissioning : May 2014

The performance of above specified FEDI 2-10-Rx system have been found to be satisfactory and meeting the requirement of our specification as per cGMP norms.

For Goldline Laboratories Pvt. Ltd.


(Dr. Ram Pramod Tiwari)

VP, Technical Operation